

990 East Mission Road  
P. O. Box 2290  
Fallbrook, California  
92088-2290  
(760) 728-1125  
Fax (760) 728-6029

**Board of Directors:**

Milt Davies  
Bob Francis  
Arne Gunnarsson  
Bert Hayden  
Mary McNeil

**Staff:**

Keith Lewinger  
General Manager

Jos. F. Jackson  
Chief Engineer

Larry E. Byers  
Administrative Services

Robert H. James  
Legal Counsel

Ruth Allen  
Board Secretary

October 22, 2001

California Regional Water Quality Control Board  
Attention POTW Compliance Division  
San Diego Region  
9174 Sky Park Court, Suite 100  
San Diego, California 92123

NPDES MONTHLY AND QUARTERLY MONITORING REPORTS FOR  
BOARD ORDER NUMBER 2000-12.

Enclosed please find the September 2001 Monthly and Quarterly Monitoring  
Reports for Board Order Number 2000-12.

Also enclosed find the City of Oceanside's September 2001 Monthly Receiving  
Water Report as requested.


On September 24<sup>th</sup>, the secondary clarifier sludge blanket came up and released  
excessive suspended solids resulting in a violation of our daily-suspended solids  
concentration and mass loading. Please note that the monthly average was not  
exceeded.

**Corrective Action:** We are presently investigating several monitoring parameters  
and treatment alternatives to prevent this type of release.

No other violations occurred during this monitoring period.

I certify under penalty of law that this document and all attachments were prepared  
under my direction or supervision in accordance with a system designed to assure  
that personnel properly gather and evaluate the information submitted. Based on  
my inquiry of the person or persons who manage the system, or those persons  
directly responsible for gathering the information, the information is, to the best of  
my knowledge and belief, true, accurate and complete. I am aware that there are  
significant penalties for submitting false information, including the possibility of  
fine and imprisonment for knowing violations.

Sincerely,

  
Joel V. Holt

Assistant Chief Plant Operator/Lab Supervisor  
cc: Joe Jackson

EX-131 P. 12-26

RECEIVED  
OCT 23 2001

## MONTHLY EFFLUENT MONITORING REPORT

DISCHARGER: FALLBROOK PUBLIC UTILITY DISTRICT

CRWQCB ORDER NO. 2000-12

NPDES NO. CA0108031

REPORT FOR: SEPT.

REPORT DUE: OCT. 31, 2001

REPORT FREQUENCY: MONTHLY

EXACT SAMPLE POINT: FILTERED EFFLUENT WELL

SAMPLE TYPE: 24 Hr. COMPOSITE

SAMPLES COLLECTED BY: FPUD STAFF

SAMPLES ANALYZED BY: FPUD LABORATORY

SIGNED UNDER PENALTY OF PERJURY:

*Joel V. Holt*

## SUSPENDED SOLIDS

REQT	CONCENTRATION (MG/L)			MASS LOADING (LBS/DAY)		
	30 DAY AVERAGE MG/L	7 DAY AVERAGE MG/L	DAILY MAXIMUM MG/L	30 DAY AVERAGE LBS/DAY	7 DAY AVERAGE LBS/DAY	DAILY MAXIMUM LBS/DAY
DATE	30	45	50	480	730	810
1-Sep-01	2.1	1.7		23.5	19.4	
2-Sep-01	2.1	1.5		24.1	17.4	
3-Sep-01	2.1	1.3	0.6	23.4	14.8	7.4
4-Sep-01	2.1	2.0	4.0	24.4	23.3	47.4
5-Sep-01	2.2	2.1	3.0	24.6	24.9	37.0
6-Sep-01	2.1	1.9	1.4	24.2	22.8	17.8
7-Sep-01	2.0	2.0	0.8	22.8	23.6	8.6
8-Sep-01	1.9	2.0		21.8	23.6	
9-Sep-01	1.9	2.0		21.6	23.6	
10-Sep-01	1.9	2.3	2.4	22.0	28.2	30.2
11-Sep-01	1.9	1.8	1.6	21.8	22.5	18.8
12-Sep-01	1.8	1.5	1.2	21.1	18.4	16.7
13-Sep-01	1.9	1.6	2.2	21.9	20.4	27.8
14-Sep-01	1.8	1.6	0.4	21.7	19.6	4.4
15-Sep-01	1.9	1.6		22.1	19.6	
16-Sep-01	1.8	1.6		21.8	19.6	
17-Sep-01	1.8	1.3	1.0	21.5	16.4	14.4
18-Sep-01	1.8	1.2	1.4	21.4	16.3	18.3
19-Sep-01	1.7	1.2	0.8	20.7	14.8	9.1
20-Sep-01	1.6	0.9	1.0	19.7	11.7	12.4
21-Sep-01	1.6	1.0	1.0	19.7	13.3	12.1
22-Sep-01	1.6	1.0		19.7	13.3	
23-Sep-01	1.6	1.0		19.6	13.3	
24-Sep-01	4.8	15.4	73.0	61.2	199.8	947.0
25-Sep-01	6.9	24.8	48.0	87.2	316.6	602.4
26-Sep-01	8.5	32.0	37.0	106.0	401.7	434.4
27-Sep-01	9.3	35.4	17.8	118.0	443.8	223.2
28-Sep-01	9.2	35.3	0.8	115.1	443.3	9.3
29-Sep-01	9.5	35.3		119.2	443.3	
30-Sep-01	10.0	35.3		124.9	443.3	
MIN.	1.6	0.9	0.4	19.6	11.7	4.4
MAX.	10.0	35.4	73.0	124.9	443.8	947.0
AVG.	3.4	8.3	10.0	41.2	104.4	124.9
VIOLATIONS	0	0	1	0	0	1